

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3550-1449:100 Page 1 of 1

CATEGORY: Door Closer/Holders/Releasing Devices

LISTEE: Glynn-Johnson, 2720 Tobey Drive, Indianapolis, IN 46219
Contact: Roger Vitt *(317) 715-4420 *FAX (317) 715-4473

DESIGN: Model 280 door holder. Unit consists of a door holder mechanism and an integral 9 V battery operated smoke detector. The unit is intended for use as a door holder when used in conjunction with a listed compatible door closer. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions and applicable codes and ordinances. Authority having jurisdiction should be consulted prior to installation.

MARKING: Listee's name, model designation and UL label.

APPROVAL: Listed as door holder for use on single swinging fire door. For use with Eveready Energizer # 522 or Duracell # MN1604 9V battery only.

*

*09-08-2003 TR



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager